



CORNERSTONE ENGINEERING

CONSULTANTS • ENGINEERS • LAND SURVEYORS

Date: March 25, 2026

File: CEI 387-24-02

To: All Interested Bidder

RE: Addendum #001 - PC Asphalt Repairs Parking Lot A&B (Gates)

Addendum #001 has been issued to reflect the following updates/changes to the bid documents.

Engineering:
Civil

1. **RFI's for this project will be accepted up until 2pm on Thursday, April 2, 2026.**

Electrical

2. Traffic control: The contractor will be responsible for providing all traffic control along College Street during the duration of Construction.

Mechanical

3. Encroachment Permit: The provided plans have been approved by the city of Porterville for construction in the right of way. However the contractor is still responsible for pulling the encroachment permit, including providing all permit fees, and bonding.

Process

Structural

4. Electrical Vaults: Below are pictures of the interior of each of the electrical vaults that the contractor will be required to lower at the south end of the project. Contractor should assume that the entire box will have to be removed and replaced, as the existing boxes have no removable rings. The lid may be reused if it is not damaged during removal. The boxes will be required to be re-installed per the details given below.

Surveying

**Project
Management**

**Staff
Augmentation**

**Drone
Services**




Figure 1: interior of electrical vault



Figure 2: interior of electrical vault



Figure 3: interior of small electrical vault



1 OLD CASTLE STD-3660 WITH TRAFFIC RATED LID

Scale: NTS

Figure 4: Large Box install detail




Figure 5: Small box install detail

Based on the survey data we have, we estimate that the large vault will need to be lowered 0.5 feet, and the small vault will need to be lowered 0.7 feet.

5. All pavement work will require seal coating prior to striping.
6. Contractor is responsible for all site security during the duration of the job. This includes securing the site and construction area during non-working hours.

A copy of this addendum with the signed acknowledgement shall be included with the contractors bid package:

Proposer's Acknowledgement

Thank You,



Claude 'Alan' Whitten, PE, PLS
Chief Civil Engineer
Cornerstone Engineering, Inc.
RCE 63332, PLS 9750